

DECLARATION OF CONFORMITY

No. S.CE/EN/0176/V4/2013/100

**KANLUX S.A., ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)**

herewith declares that the product:

CIRCUIT-BREAKER FOR OVERCURRENT PROTECTION**Type / types:** **KS6 B2..B32 /1, KS6 C4..C32 /1,
KS6 B6..B63 /3, KS6 C6..C63 /3****Trade mark:** **Kanlux****Basic parameters:** $U_c = 230/400V\sim (1P), 400V\sim (3P);$
 $I_n = 1..63A; \text{typ B, C; } I_{cn} = 6000A;$
Energy limiting class - 3**is in conformity with the provisions of the following EC directive(s)**
(including all applicable amendments):**Directive (LVD) – 2006/95/EC****Directive (RoHS) – 2011/65/EC**references of standards and/or technical specifications applied for this declaration
of conformity:**EN 60898:2003 +A1:2004 +A11:2005 +A12:2008 +A13:2012****Additional information:**Kanlux S.A. has an implemented Quality Management system according to norm **ISO 9001:2008**
confirmed by ISO certificate PL8000069 issued by Bureau Veritas Certification Polska Sp. z o.o.Last two digits of the year in which the CE marking was affixed: **07****NWP/072; ID 0176; S.CE/100****Radzionków, 23.05.2013**

Kanlux S.A.
Kierownik Działu Technicznego
Dariusz Staniczek
Kanlux S.A.
Kierownik Laboratorium Badaawczego
Krzysztof Żurek
Kanlux S.A.
Specjalista ds. Wdrożenia
i Certyfikacji produktów
Adam Wabnic

.....
name and function of the signatory